



INSULATION RESISTANCE TEST REPORT

Client	KB Job #
Location	Date
Switchgear	Testing Equipment: Manufacturer/Model
	Calibration Date
	Temperature / Humidity
	F/ %
	Tested By

Test Data

Equipment Name / Feeder	A-G	B-G	C-G	A-B	B-C	C-A	Notes
	Visual & Mechanical Inspection*				PASS		
	Cable Phasing				B,O,Y		
	Visual & Mechanical Inspection*				PASS		
	Cable Phasing				B,O,Y		
	Visual & Mechanical Inspection*				PASS		
	Cable Phasing				B,O,Y		
	Visual & Mechanical Inspection*						
	Cable Phasing						
	Visual & Mechanical Inspection*						
	Cable Phasing						
	Visual & Mechanical Inspection*						
	Cable Phasing						
	Visual & Mechanical Inspection*						
	Cable Phasing						

All Readings are in Megohms (MΩ) unless otherwise noted

*Visual & Mechanical inspections include: Comparing cable data with drawings, Inspection for damage, Proper taping is used, Proper type and size of lug is used, and proper strain relief for conductors at the terminations (mark PASS or FAIL)

Notes:
